

07-12-89

ACTION ITEMS ON THE GIVEN DATE FOR WALKDOWN

PAGE 3

ITEM NO.	Group	Person Assigned	Issue Date	Due Date	Pri	Cde	Area/Item Desc	Action Desc	S	C Status	Comp Date
CONDENSER											
2474	OPER		07-10-89	07/17/89			MAIN CONTROL BLDG UNIT 2 AND BOILER BOTTOM ASH CONTROL AREA	GENERAL			
2475	OPER		07-10-89	07/17/89			MAIN CONTROL BLDG UNIT 2 AND BOILER BOTTOM ASH CONTROL AREA	RETURN TO BACK UP SHOP			
2482	OPER		07-10-89	07/17/89			MAIN CONTROL BLDG UNIT 2 AND BOILER 5TH LEVEL, AIR COLUMN M202	PICK UP LAYING ON			
2415	OPER	DAVIS, ROBERT	07-10-89	07/17/89			MAIN CONTROL BLDG UNIT 2 AND BOILER OPERATOR OFFICE AREA - 1ST FLOOR	REMOVE W			
**											
2478	TECH	HINTZE, JERRY	07-10-89	07/17/89			MAIN CONTROL BLDG UNIT 2 AND BOILER	FIND OUT WHICH TESTS ARE SCHEDULED FOR THE BOILER. THERE AR E STILL A LOT OF TEST RUNS OF THERMOUCUPLE WIRE ON THE BOIL ER.			
2483	TECH	HINTZE, JERRY	07-10-89	07/17/89			MAIN CONTROL BLDG UNIT 2 AND BOILER	CHECK ON THE STATUS OF THE PYROSONICS SYSTEMS ON BOTH BOILER S			
**											
20 records listed.											

BILL & AARON 118WOULD YOU PLEASE
HANDWRITE ME A SHORT
RESPONSE TO THESE ITEMS

JKS

A complete testing series is still scheduled
to be conducted on both Unit 1 and 2this fall (Sept-Oct) for the Boiler,
(Combustion/O₂ profiles), Air Headers,plus pulverizers (rotating shafts and
variable loading), and fans (PAFFD).

The majority of all test equipment and

thermocouples are setup ~~for~~ permanentlyfor routine testing ^{not} intent, thus, TIC's

are ran in conduct to termination boxes.

If possible, please list specific problem

areas to determine if they are ours

originally so that these walkdown concerns

can be resolved.

Aaron

Bill will address other note.

IP7_004410